

SC 106

3" SEWERS

4X2" FLOOR DRAIN - VENT

UNFINISHED BASEMENT AND BATH

RADON VENT !!!!!!! STUB 3" OUT OF FOUNDATION

**INDIRECT FD NEEDED - ON REGULAR FD , PUT 3X2 TEE
AND RUN A 2" LINE AND TURN UP A
90 OUT OF FOUNDATION**

